



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22862128, Fax No.080-22862126,
E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in
No: GM (Q, S&S)/DGM-4/BC-11/17-18/ | **CYS-66**
Encl:

O/o GM(QS&S)
No:12, J.P Avenue, Curve
road, Tasker Town,
Bangalore-51

Date: **01-07-2017**

OFFICIAL MEMORANDUM

- Sub : Vendor approval to M/s Vijay Power Control Systems, Bangalore for supply of BEE 4 star (OLD) rated 25kVA Distribution Transformers.
- Ref : 1. Approved by Director (Technical) vide para (10) dated: 30.06.2017 of T.O Note No: GM (QS&S)/DGM-4/BC-11/2017-18/1111 dated: 30.06.2017.
2. Firms letter dated: 16.06.2017.


Approval is hereby accorded to M/s Vijay Power Control Systems, B-65 & P-16, 3rd Cross, 3rd Stage, Peenya industrial Estate, Bangalore-560 058, as approved vendor for supply of BEE 4 star (OLD) rated 25kVA Distribution Transformers to prospective consumers in BESCOM area for self -Execution works, Turnkey works & Partial Turnkey works in BESCOM Jurisdiction.

Sl. No.	Particulars	Period of validity upto
1.	25kVA, BEE 4 star (OLD) rated (EEL-2) Distribution Transformers, 50Hz, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	31.05.2022 (Subject to revalidation every year)

The approval is subject to the following conditions:-

1. The prospective consumers who purchase above said Distribution transformers shall stand guarantee for the materials for a period of one year from the date of commissioning.
2. The above transformers shall confirm to the specification as prescribed in the relevant IS/IEC & its amendment from time to time.
3. The above said transformers shall be got inspected by QS&S or the concerned jurisdictional Engineers, BESCOM before they are put into service.
4. BESCOM reserves the right to withdraw the approval issued, in case of any violation of the approved drawing and specification at any time.
5. To maintain loss level as per latest amendments vide gazette notification No: S.O 4062(E) dated: 16.12.2016 by Ministry of Power, GOI in consultation with BEE.
6. Stainless steel plate of 5" x 2" dimensions with unique ID code shall be welded on the tank of the transformer.
7. For renewal of vendor approval proposal shall be submitted one month prior to expiry of validity of vendor approval.

Approved by Director (Technical)


(G. Sheela)
General Manager (El.,)
Q, S & S BESCOM.

Copy to-

1. The Chief General Manager (El.,) CA / Operations/ Projects, BESCOM, Bangalore.
2. All the Chief Engineer (Electy..) O&M Zones, BESCOM.
3. The General Managers (Ele..) Procurement / DAS, BESCOM.
4. All the Superintending Engineers (Ele), CO&M circles, BESCOM.
5. All the Executive Engineers (Ele.) CO&M Divisions, BESCOM.
6. PS to DT to place before Hon'ble Director (Technical), BESCOM.
7. M/s Vijay Power control systems, B-65 & P-16, 3rd Cross, 3rd Stage, Peenya industrial Estate, Bangalore-560 058.
8. OC/MF.