



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,  
E-Mail [gmqs.work@gmail.com](mailto:gmqs.work@gmail.com) , [gmqs@bescom.co.in](mailto:gmqs@bescom.co.in)  
No: GM(QS&S)/DGM(El.,)-3/BC-11/18-19/189  
Encl:

O/o GM(QS&S)  
Corporate Office, K.R. Circle  
Bangalore-51  
Date: 11-02-2019

**OFFICIAL MEMORANDUM FOR VENDOR APPROVAL**

Sub :	Vendor approval to M/s Vijay Power Control Systems, Bangalore for supply of 63kVA, 100kVA, 250kVA and 500kVA star2 rated (EEL-3/5 star rated) Distribution Transformer.
Ref :	1. Approved by Director (Technical) vide para (35) dtd: 07.02.2019 of T.O Note No: GM (QS&S)/DGM-3/BC-11/2018-19/1769 dtd: 09.10.2018. 2. Firm Letter No:NIL Dated:16.04.2018 3. BIS License No: CML-620117689 dtd:23.01.2019

\*\*\*\*\*

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


Sl. No	Name of the Firm/ Address/Contact details	Equipment/Materials	Period of validity upto
1.	M/s Vijay Power Control Systems, B-65 & P -16, 3 <sup>rd</sup> Stage Peenya Industrial Estate, Bangalore - 560058 (Ph No: 9180 28365631) (E-mail: <a href="mailto:info@vijaytransformers.com">info@vijaytransformers.com</a> ).	63kVA, 100kVA & 250kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	16.08.2023 (Subject to revalidation every year)
2.		500kVA star2 rated (EEL-3/5star rated), Distribution Transformers, 50Hz, CRGO Core, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS - 1180 & IS - 2026.	20.12.2023 (Subject to revalidation every year)

**The approval is subject to the following conditions:-**

1. This O.M is issued only to enlist the firm in vendor list of the BESCOM to manufacture the above star rated Distribution Transformers and the star marking on the product is liable to condition of BIS license
2. The prospective consumers who purchase above said material shall stand guarantee for the materials for a period of one year from the date of commissioning.
3. The vendor shall furnish all the relevant valid type test reports (as per IEC/IS/Technical specification & its amendment from time to time) of not older than 5 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be got inspected by QS&S or the concerned jurisdictional Engineers, BESCOM before they are put into service.
6. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance / technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
7. Stainless steel plate of 5" x 2" dimensions with unique ID code shall be welded on the tank of the transformer.
8. For renewal of vendor approval proposal shall be submitted one month prior to expiry of validity of vendor approval.

**Note:** Earlier issued OM's vide No: GM(QS&S)/DGM-3/BC-11/18-19/CYS-115 dtd:15.10.2018 & CYS - 169 dtd:14.01.2019 stands cancelled.

Approved by Director (Technical)

  
(Nagarajah. B.N)  
General Manager (El.,)  
Q, S& S BESCOM.

Copy to-

1. The Chief General Manager (El.,) CA / Operations/ Projects, BESCOM, Bangalore.
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Managers (Ele.,) Procurement / DAS, BESCOM.
4. All the Superintending Engineers (Ele), CO&M circles, BESCOM.
5. All the Executive Engineers (Ele.) CO&M Divisions, BESCOM.
6. PS to DT to place before Hon'ble Director (Technical), BESCOM.
7. M/s Vijay Power Control Systems, B-65 & P -16, 3rd Stage Peenya Industrial Estate, Bangalore - 560058
8. OC/MF.