

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED****(Wholly owned by Government of Karnataka Undertaking)**

Telephone No. 080-22252128

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM (QS&S)/DGM-3/AE/BC-11/24-25/

Encl:

O/o GM (QS&S)

Corporate Office

K R Circle, BESCOM

Bangalore-560 001

Date:

18 MAY 2024**OFFICIAL MEMORANDUM**

Sub : Renewal of Vendor approval to M/s Vijay Power Control Systems Private Limited, Bangalore for supply of 25kVA 63kVA, 100kVA & 250kVA EEL-2 (2 star rated) Distribution Transformer as per Amendment 4 of IS-1180

Ref : 1. Firm Letter dated: 14.08.2023 & 06.05.2024.

2. Approved by Director (Technical) vide para (20)/330 dtd: 16.05.2024 of T.O Note No: GM (QS&S)/DGM-3/AE/BC-11/24-25/433 dtd: 16.05.2024.

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the following material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.


Sl No	Name of the Firm/ Address/ Contact details	Equipment/Materials	Period of validity upto
1	M/s Vijay Power Control Systems Private Limited, B-65 and P 16, 3 rd cross, 3 rd stage, Peenya Industrial Estate, Bangalore – 560058 Ph:91 80 28361273/ 91 80 28365631 E-mail: info@vijaytransformers.com	25kVA & 63kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	28.06.2028 (Subject to revalidation once in 2 years from the date of issue of this OM)
2		100kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	27.09.2028 (Subject to revalidation once in 2 years from the date of issue of this OM)
3		250kVA EEL-2 (2star rated) Distribution Transformers as per new amendment 4 of IS 1180, 50Hz, CRGO Core, Aluminium Wound, ONAN Cooled, complete with first filling EHV Grade Transformer Oil with all accessories and confirming to latest versions of IS – 1180 & IS – 2026.	08.11.2028 (Subject to revalidation once in 2 years from the date of issue of this OM)

The approval is subject to the following conditions:-

1. This O.M is issued only to enlist the firm in vendor list of the BESCOM to manufacture the above star rated Distribution Transformers and the star marking on the product is liable to condition of BIS license and the firm shall produce the valid BIS license & BEE license before supplies are made.
2. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.

3. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Testing houses only and Vendor approvals are considered based on type test reports.
4. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
5. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
6. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
7. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
8. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality/defective materials/ equipment to BESCOM projects, poor performance, poor after sales service, etc.
9. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
10. Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
11. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
12. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)


(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore
2. All the Chief Engineer (Electy.), O&M Zones, BESCOM.
3. The General Manager (El.), Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s Vijay Power Control Systems Private Limited, B-65 and P 16, 3rd cross, 3rd stage, Peenya Industrial Estate, Bangalore - 560058
8. Office copy / M.F.